

Hardware Mounting Locations

| | | |
|---|--------------|--|
| Locks, Latches, Roller Latches and Double Handle Sets | | 38" – 42" (965 mm – 1067 mm) Centerline of Lock Strike form Bot- tom of Frame |
| Rim and Mortise Panic Devices | | |
| Cylindrical and Mortise Deadlocks ⁽¹⁾ | | 48" (1219 mm) to Centerline of Strike from Bottom of Frame |
| Push Plates | | Centerline 45" (1143 mm) from Bottom of Frame |
| Pull Plates | | Centerline of Grip @ 42" (1067) from Bottom of Frame |
| Combination Push Bar | | Centerline of 42" (1067 mm) from Bottom of Frame |
| Hospital Arm Pull | | Centerline of Lower Base is 45" (1143 mm) from Bottom of Frame with Grip Open at Bottom |
| Hinges | Top | Up to 11-3/4" (298.5 mm) from Rabbet Section of Frame to Center- line of Hinge |
| | Bottom | Up to 13" (330.2 mm) from Bottom of Frame to Centerline of Hinge |
| | Intermediate | Equally Spaced Between Top and Bottom Hinges |

⁽¹⁾ Cylindrical and Mortise Deadlock strikes shall be located at 48" (1219 mm) from the bottom of the frame unless otherwise specified.